



**State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES**

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095
(603) 271-3503 FAX (603) 271-5171



February 7, 2003

LETTER OF DEFICIENCY #WSEB 03-019
CERTIFIED MAIL 7099 3400 0003 0691 1505

Sylvia Blakslee
Winmiir Condominium Association
PO Box 334
Mirror Lake, NH 03853

Subject: Tuftonboro - Public Water System: Winmiir Condos Association (EPA# 2372050)

Dear Ms. Blakslee:

The records of the Department of Environmental Services (DES) show that the Winmiir Condos Association water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system serving 15 or more services, or 25 or more people for 60 or more days per year. As such, the water system owner is required to submit samples to the State laboratory or a State-certified laboratory for coliform bacteria analysis in compliance with NH Administrative Rule Env-Ws 325.

DES records show that Standard Maximum Contaminant Level (MCL) violations for total coliform bacteria, as defined in NH Admin. Rule Env-Ws 315.01 have occurred and that letters of violation were issued for the following months:

December 2002 and January 2003

DES believes the MCL violations can be corrected and future violations prevented by taking the following actions:

- By February 17, 2003**, retain the services of a qualified water system consultant to address the system's water quality problems relative to the recent bacteriological occurrences; and
- 2. By March 3, 2003**, submit to DES for review a copy of the consultant's report which shall include recommendations to correct the bacteria contamination; and
- 3. By March 10, 2003**, submit to DES for review and approval an implementation schedule which identifies specific dates by which steps to correct the bacteria contamination will be accomplished.

In the event compliance is not achieved within this period, DES may take further enforcement action, including issuing an order requiring the deficiencies be corrected, initiating an administrative fine proceeding and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

Letter of Deficiency #WSEB 03-019
Winmiir Condos Assoc.
February 7, 2003
Page 2 of 2

The copy of the consultant's written report **and the implementation schedule** as requested above should be addressed as follows:

Alan Leach
Department of Environmental Services
Water Supply Engineering Bureau
6 Hazen Drive, P.O. Box 95
Concord, NH 03302-0095

Please contact Alan Leach by phone at (603) 271-2854, or by e-mail at aleach@des.state.nh.us if you have any questions regarding this letter.

Sincerely,

A handwritten signature in black ink, appearing to read 'Anthony P. Grunta', is written over a large, bold, black 'COPY' stamp.

Anthony P. Grunta, P.G., Administrator
Water Supply Engineering Bureau

h:\wseb\enfmon\enforce\lods\bact\2372050 mcl lod 03-019.doc

cc: Gretchen Rule, DES Legal Unit
David Senecal, Health Officer, Town of Tuftonboro
Shannon Morin, Primary Operator
EPA Region I